

Overview

- According to EN 61558-2-4, -2-2, -2-1
- **CE, cULus**¹⁾
- 4AM: $t_a = 40\text{ °C/B}$, 4AT: $t_a = 55\text{ °C/H}$
- AC 50/60 Hz
- Degree of protection IP00, IP23 and IP54



¹⁾ **cULus** approvals for voltages $\leq 600\text{ V}$ (including tappings).



4AM with screw terminals/flat connection (figure on the left) and 4AT with screw terminals (figure on the right)