



BETA Switching Switches and Light Indicators

Product overview

Overview

Devices	Page	Field of application	Standards	Used in		
				Non-residential buildings	Residential buildings	Industry
	7/3	For the switching of illumination and other electrical devices up to 20 A. For use in control cabinets for the logical linking of functions.	IEC/EN 60947-3, (VDE 0660-107); IEC/EN 60669-1, (VDE 0632-1); GB14048.3-2002 CCC	✓	✓	✓
	7/7	To be used as pushbuttons in control systems, e.g. to switch on seal-in circuits or as pushbuttons with maintained-contact function for manual use, as control switches or for the switching of loads up to 20 A.	IEC/EN 60947-3, (VDE 0660-07); IEC/EN 60669-1, (VDE 0632-1); GB14048.3-2002 CCC	✓	--	✓
	7/12	Light indicators for signaling switching states or faults in systems.	VDE 0710-1	✓	--	✓
	7/15	For the switching of lighting, motors and other electrical devices from 20 to 125 A.	16 A ... 25 A and 40 A ... 100 A: IEC/EN 60947-3, (VDE 0660-107); IEC/EN 60669-1, (VDE 0632-1) 32 A and 125 A: IEC/EN 60947-3, (VDE 0660-107); GB14048.3-2002 CCC	✓	✓	✓
	7/22	For fast and safe connection	IEC/EN 60439-1, (VDE 0660-500)	✓	--	✓
	7/24	For the switching of lighting, motors and other electrical devices or for switching system components from 100 to 200 A.	IEC/EN 60947-3; KEMA certified UL 508	✓	--	✓