

BETA Measuring Three-Phase Measuring Devices

E-counters

Schematics

Grounding terminal

The grounding terminals required for the transmission technology for 7KT1 520 and 7KT1 521 versions only serve to shield the transmission cables and do not have a protective function.

Rate switchover

If there is a voltage of 230 V AC at terminals 4 and 5, the rate is switched to 2.

Instructions for the connection of transformer counters

In the case of cross-section reduction, a short-circuit resistant cable is required for the power supply of terminals L 1, L 2 and L 3 depending on the fusing for phases L 1, L 2 and L 3. A fuse of 6 A is recommended for line protection.

Current transformers must not be operated with open terminals as this can result in dangerously high voltages, which may cause personal injury and/or property damage. It can also lead to a thermal overload of the transformers.

